

REPUBLIKA NG PILIPINAS KAGAWARAN NG PANANALAPI

KAWANIHAN NG INGATANG-YAMAN

(BUREAU OF THE TREASURY) Intramuros, Manila

BIDS AND AWARDS COMMITTEE Supplemental Bid Bulletin No. 12-2022

August 25, 2022

Supply, Installation and Commissioning of Back-up Power System for the Bureau of the Treasury Pampanga office ITB-29-2022-G

This Supplemental Bid Bulletin No. 12-2022 is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents.

| REFERENCE | AMENDMENTS/CHANGES |
|---|---|
| Section VII. Technical Specifications | Section VII. Technical Specifications |
| Item 4. PROJECT REQUIREMENTS | Item 4. PROJECT REQUIREMENTS |
| 1.1.1. Generator Set – 1 unit | 1.1.1. Generator Set – 1 unit |
| Sound Level: 70dB @7 meter | Sound Level: Maximum of 70dB 80dB @7 meter |
| 1.1.2. Generator Set Cage – 1 lot | 1.1.2. Generator Set Cage – 1 lot |
| | To add: Enclosure must ensure that the generator will be protected on changes in the region weather conditions. |
| 1.1.3. Automatic Transfer Switch – 1 unit | 1.1.3. Automatic Transfer Switch – 1 unit |
| Type: Solenoid Type | Type: Solenoid Breaker Type |
| 1.1.4. Uninterruptible Power Supply – 1 lot | 1.1.4. Uninterruptible Power Supply – 1 lot To add: (Maximum of three (3) paralleled units) |
| Total Runtime: 10 minutes at full load | Total Runtime: 40 15 minutes at full 50% load |
| Section VII. Technical Specifications | Section VII. Technical Specifications |
| Other Conditions and Requirements | Other Conditions and Requirements |
| Bidder's Qualifications | Bidder's Qualifications |
| 1.4. The Contractor shall complete the delivery and installation of works within 120 calendar days from the date of receipt of Notice to Proceed. | 1.4. The Contractor shall complete the delivery and installation of works within 420 150 calendar days from the date of receipt of Notice to Proceed. |

ISO 9001:2015 Quality Management System Certificate No. AJA17-0071

| CLARIFICATIONS | RESPONSE |
|--|------------------------------------|
| 1. The bidder must be a certified partner for the product being offered. Certification issued by the principal or local distributor of the proposed equipment stating that the bidder is "the authorized reseller and support provider in the Philippines" | Both for UPS and Generator Set. |
| Query: Is this pertaining to UPS equipment only? | |
| Certification from the principal of the proposed equipment is "willing to extend support to the Bureau of the Treasury for the product being offered" | 2. Both for UPS and Generator Set. |
| Query: Is this pertaining to UPS equipment only? | |

The Procuring Entity notes all other issues and concerns raised by the bidders not related to the Technical Specifications of the project, which are not directly addressed in this Bid Bulletin. The end-user will provide the necessary assistance and documents to ensure smooth implementation of the project.

For guidance and information of all concerned.

ATTY. GISELA F. LOOD (Sgd.)
Deputy Treasurer of the Philippines and
Chairperson, Bids and Awards Committee

